



- NOTES:**
1. TEMPORARY BLOWOFF ASSEMBLY TO BE PERMANENT AFTER 2 YEARS.
 2. POLY WRAP ALL DIP AND FITTINGS
 3. USE BOXLOK OR VALVE BOX ADAPTOR II FOR CENTERING BOXES OVER VALVES.

WATER MAIN SIZE	TEMPORARY BLOWOFF PIPING SIZE	PERMANENT BLOWOFF PIPING SIZE
2"	2"	2"
4"	2"*	POST
6"	2"*	FIRE HYDRANT
8"	2 1/2"**	FIRE HYDRANT
10" OR GREATER	FIRE HYDRANT	FIRE HYDRANT

NOTE: ALL FIRE HYDRANTS SHALL HAVE A MINIMUM OF 500 GPM.
 * POST-TYPE HYDRANT MAY BE USED. MUST PROVIDE A MINIMUM OF 250 GPM.
 ** BCWS WILL PERMIT USE OF A POST-TYPE HYDRANT ON A CASE-BY-CASE BASIS.

BLOWOFF ASSEMBLY
 NOT TO SCALE

WATER PANEL 5

**BERKELEY COUNTY WATER AND SANITATION
 POTABLE WATER & SANITARY SEWER STANDARDS**

REVISED 04/25/2023